

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0001		3. EFFECTIVE DATE 05/12/08	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 07-0100
6. ISSUED BY Resident Officer in Charge of Construction 1005 Michael Road Camp Lejeune, NC 28547-2521		CODE mks	7. ADMINISTERED BY (If other than Item 6) See Item 6	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-07-R-0100
			X	9B. DATED (SEE ITEM 11) 05/06/08
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

07-0100, Construct Rooms, Bldg. 797

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Sheet A1 Provide motorized operators for doors 1 and 3. Provide push type switches on both sides of each door. Operators and switches shall be in compliance with ADA. Provide battery backup to operate doors incase of loss of power to door operator circuit. Provide 20 amp circuit feed from panel LA to door operators. Provide operators with integral disconnects. Directions given here assume that the top of the drawing faces North.

Provide an additional door in the south wall of room 5. Door shall be identical to door 10, except for swing. Locate door at east end of the south wall. Provide an additional door in the plan north wall of room 7. Door shall be identical to door 10, except for swing. Locate door at west end of the north wall.

2. Sheet E4 Change panel LA from 125 amp to 200 amp with four 3/0 and #6 grnd in 3" conduit to transformer. Demolish existing step down transformer. Provide 75KVA 480/120V three phase dry transformer with four #1 and # 6 grnd in 2" conduit to MDF. Provide 125 amp three pole breaker in MDF. Provide 4 x 4 x 2 telephone boxes with 4 x4 to 2 x 4 reducing plaster rings. Combination electrical and telephone boxes as shown are not acceptable. Provide 1" conduits from rack to telephone outlets instead of the 1-1/2" shown. Provide 8 additional telephone outlets in locations as directed by the contracting officer. Provide four 120 V 20 amp branch circuits each with one 20 amp rated duplex receptacle 48" AFF in room 9.