

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0004		3. EFFECTIVE DATE 09/17/08	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 06-0058
6. ISSUED BY CODE		ase	7. ADMINISTERED BY (If other than Item 6) CODE	
Officer in Charge of Construction 1005 Michael Road Camp Lejeune, NC 28547-2521		See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-06-R-0058
			x	9B. DATED (SEE ITEM 11) 09/06/08
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
(a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;  
or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

06-0058, Major Interior/Exterior Repairs, BEQ HP275 & HP285

CONTINUED

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Perform all work indicated on the reference drawings (NAVFAC Drawing Nos. 60001551-60001561).
2. Delete the make up air system from the discharge of both MAU's to the individual rooms.
3. Provide 16 x 16 duct from MAU1 to the third floor mechanical room located closest to MAU1. Provide 16 x 16 duct from MAU2 to the third floor mechanical room located closest to MAU2. Provide VAV with 12" dia duct in each mechanical room to supply 560 CFM to the mixing box of each of 6 AHU's. Provide 14 x 14 duct from downstream side of VAV takeoff to second floor mechanical room. Provide 12 x 12 duct from downstream side of VAV takeoff to first floor mechanical room. Provide additions to the controls to operate the VAV boxes. On signal from emergency shut off close VAV box damper.
4. Provide Fire dampers at all exhaust and supply ducts penetrating concrete floor or roof slabs or concrete planks.
5. In cooling mode reset reheat temperature from MAU's based on the load on the AHU's.
6. Provide complete DDC system to control MAU's, VAV's, Terminal Air Blenders, AHU's, pumps, chiller, and TE heat exchangers.
7. See Crockford drawings for extensions to MAU outside air intakes and exhausts.