

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0006		3. EFFECTIVE DATE 09/19/08	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 06-0058	
6. ISSUED BY CODE		ase	7. ADMINISTERED BY (If other than Item 6) CODE		
Officer in Charge of Construction 1005 Michael Road Camp Lejeune, NC 28547-2521			See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-06-R-0058
				x	9B. DATED (SEE ITEM 11) 09/06/08
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

06-0058, Major Interior/Exterior Repairs, BEQ HP275 & HP285

The time and date for receipt of proposals is changed to not later than (NLT) 1230, Friday, 19 September 2008.

CONTINUED

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

The scope of Electrical and HVAC work is as follows:

From the Davis and Floyd Drawings:

1. Demolish existing exhaust system as shown on M1 and M2.
2. Demolish existing air handlers as shown on M3. Note that work at HP267 shown on M3 was deleted by previous amendment.
3. M4 and M5 provide all work except for the outside air supply to the sleeping rooms. The outside air supply to the rooms was deleted by previous amendment. By previous amendment the outside air supply was directed to the mechanical rooms, and metered to the air handlers via VAV boxes. Please note that M4 and M5 require new exhaust systems from the make up air units to the sleeping rooms.
4. M6 Provide all work except for the work shown in the HP267 detail. Note dehumidifiers in each mechanical room.
5. M7 Provide all work. Note the revisions to the make air unit supply system discussed for sheets M4 and M5
6. M8 Provide all work except for pumps p1a, p1b, hp1a, hp1a, hp1b, cp1a, cp1b, and cp1c; and supply grills. Work provided from this sheet includes TE 1 circulating pump, six air handlers, six dehumidifiers, two make up air units, and return grills.
7. M9 Provide all work except end suction pump.
8. M10 Provide work indicated for barracks and asbestos work. Limit work to HP275 and HP 285; and the domestic hot water buildings serving these two buildings.
9. M11 Provide all work.
10. From electrical drawings provide the electrical items required to power the equipment installed under the Davis and Floyd mechanical drawings. This work includes feeders and disconnects for the dehumidifiers, make up air units, and hot water pumps for TE 1s; and wiring from existing disconnects to the new air handlers and power for new controls.

From the Crockford drawings:

11. PM1 Provide all work
12. M1 Provide all work. Note that previous amendment deleted notes 2 and 4.
13. M2 Provide all work.
14. M3 Provide make up air unit exhaust and intake ducts; and roof intakes and roof exhausts.
15. M4 Demolish existing terminal air blenders and existing return grills in sleeping rooms. Patch and paint ceiling. Provide terminal air blenders. Delete return duct on back of fan powered boxes. Provide 12 x 12 ceiling mounted return in each closet. That is two returns per sleeping room. Provide new access door for fan powered boxes. Size door as required for servicing fan powered boxes and access to electrical. Provide whip from existing junction box to new fan powered boxes. Provide new ducts from existing take offs on trunk ducts to fan powered boxes and new ducts from fan powered boxes to existing diffusers.

16. M5 Provide all work. Change minimum air flow for all fan powered boxes to 45 CFM.
17. M6,M7 and M8 Provide control work under Pressure-Independent Terminal VAV Box with velocity controller. All other control work shall be as per the Davis and Floyd drawings.
18. E1 delete notes 1 and 2. Provide all work.
19. E2 Provide all work.
20. E3 Provide all work.
21. E4 Provide all work.
22. E5 Provide all work.
23. Provide all other work as per plans and specifications.