

**NAVFAC
SPECIFICATION**

P171 Squadron Facilities

AMENDMENT NO. 0002

IMPORTANT

This amendment should be acknowledged when your bid is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the bid.

If your bid has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your sealed bid is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to bid opening time.

2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 9/10/08	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
---------------------------------------	------------------------------	----------------------------------	--------------------------------

6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533	Code N62470	7. ADMINISTERED BY (If other than item 6.) Code
--	-------------	--

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR BID	<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION P171
	<input type="checkbox"/>	9B. DATED (SEE ITEM 11) 8/20/08
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
	<input type="checkbox"/>	10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers is extended is not extended . Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

- A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
- C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
P171 SQUADRON FACILITIES, MARINE CORPS AIR STATION, CHERRY POINT, NORTH CAROLINA

This amendment is issued to provide responses to questions received. See Continuation Sheet.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Same as Item 8) _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED

CONTINUATION PAGE
AMENDMENT 0002
P171 SQUADRON FACILITIES

Q: Page A001 of the drawings under finishes calls for Bonc White or natural anodized. The specs call for a two-coat paint to be determined. Which is correct?

R: Provide an organic coating per Section 08 51 13, paragraph 2.2.6. Color to be White.

Q: Will the exterior doors and side lites (all buildings) (be ¼” laminated or blast proof?

R: Provide all exterior door vision panels with ¼” laminated glazing per Section 08 81 00, paragraph 2.1.3. Provide all exterior sidelight frames with 1” insulating glass units per Section 08 81 00, paragraph 2.2.

Q: MACS ATC – The windows are referenced as Type A windows. The width of the windows and the rough opening on the floor plan are the same as Type B. Which is correct?

R: Revise all exterior window symbols from “A” to “B” on NAVFAC Drawing 12522859 to match window elevation on NAVFAC Drawing 12522886.

Q: MACS ATC – Page 603, elevation B shows a fixed unit and page 203, elevation shows which is supposedly a single hung unit. Which is correct?

R: Revise window elevation “B” on NAVFAC Drawing 12522886 to single-hung type to match building elevations on NAVFAC Drawing 12522866 and window details on NAVFAC Drawing 12522888.