



September 27th, 2011

Winston Hospitality
Attn: Bill Kibbe, Snr. Project Manager
4900 Waters Edge Drive
Suite 270
Raleigh, NC 27606

PRE-CONST. RFI RESPONSE :: RFI # 1

Re: **Hampton Inn & Suites**
Jacksonville, NC
RFI # 1
Electrical E1 & E2

From: Steven Finch; Associate AIA, LEED AP, Hospitality Project Manager

Pro Construction Question:

RFI-E1

- Plan sheet E1.2 General Note 9 mentions NM Cable.
- Plan sheet E2.1-E2.3 Note 1 mentions MC Cable
- Is NM cable allowed in lieu of MC Cable?

RFI-E2

- Plan sheet E3.0 Detail 2-Pole Bases.
- Notes States: "All Site Lighting to be Leased From Local Utility"
- Who will be responsible for Pole Bases?

RBA Response:

- E1 :: Type NM cable is allowed in the guestrooms as long as the construction type for the guestroom is type III, IV, or V. Every jurisdiction interprets the code differently; therefore the permissibility of this should be verified with the local inspector, plans reviewer and Hilton. It is our interpretation that NM is allowed by code and Hilton but this must be re-verified at time of construction with Hilton's CA P.M. and in field Electrical Inspector.
- E2 :: Progress will be providing the bases, poles and fixtures.

Steven E. Finch, AIA, LEED AP
Director of Hospitality
RBA Group :: Architecture - Interiors
1414-A S.Tryon St.
Charlotte, NC, 28203
p. 704.344.9098 x 112
sfinch@therbagroup.com
www.therbagroup.com