



RBA GROUP
ARCHITECTURE+INTERIORS

September 27th, 2011

Winston Hospitality
Attn: Bill Kibbe, Snr. Project Manager
4900 Waters Edge Drive
Suite 270
Raleigh, NC 27606

PRE-CONST. RFI RESPONSE :: RFI #3

Re: **Hampton Inn & Suites**
Jacksonville, NC
RFI # 3
Door Schedule Clarifications

From: Steven Finch; Associate AIA, LEED AP, Hospitality Project Manager

Pro Construction Question:

1. The door schedule on A9.1 is calling for aluminum doors to be labeled with between 20min & 60min ratings. Aluminum doors and frames do not carry any fire rating, please advise.

RBA Response:

<u>Door Number ::</u>	<u>Location ::</u>	<u>Frame ::</u>	<u>Hourly Rating ::</u>
15	Pantry	Aluminum	No Rating
25	Ext. Vestibule	Aluminum	No Rating
27	Int. Vestibule	Aluminum	No Rating
42	Fitness	Hollow Metal	45 min.
44	Int. Vestibule	Aluminum	No Rating
45	Ext. Vestibule	Aluminum	No Rating
52	Vending	Hollow Metal	60 min.
54	Guest Laundry	Hollow Metal	60 min.

Steven E. Finch, AIA, LEED AP
Director of Hospitality
RBA Group :: Architecture - Interiors
1414-A S.Tryon St.
Charlotte, NC, 28203
p. 704.344.9098 x 112
sfinch@therbagroup.com
www.therbagroup.com