

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 2
2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 12-Aug-2008	4. REQUISITION/PURCHASE REQ. NO. W31RYO81028949		5. PROJECT NO.(If applicable)
6. ISSUED BY US ARMY ENGINEERING & SUPPORT CENTER CEHNC-CT 4820 UNIVERSITY SQUARE HUNTSVILLE AL 35816-1822	CODE W912DY	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W912DY-08-R-0020	
		X	9B. DATED (SEE ITEM 11) 14-May-2008	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to execute the following changes: A. The attached questions and answers are hereby incorporated into the solicitation. B. The proposal due date is extended to August 19, 2008, 12:00 CDT. C. All other terms and conditions are to remain unchanged.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 12-Aug-2008

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES**The following items are applicable to this admendment:**AMENDMENT 4 VERBIAGE

1. This Amendment is being issued to make the following changes:

a. Incorporate Questions and Reponses posted to ProjNet into the RFP as follows:

- i. Question: There are some requirements for HAZMAT office & storage space in some of the reference documents. It appears that when they downsized for the SF allotment, they deleted these spaces. Please confirm.

Response: Yes, the HAZMAT Office and Storage Room was deleted for the Fort Stewart Fire Station.

- ii. Question: Is there a requirement for a vehicle maintenance bay and storage on this project?

Response: No, there is no requirement for a Maintenance Bay and Storage in this project. The only storage required is the Equipment Storage Building which is 1,190 SF. This was taken out of the 20,212 SF given in the 1391.

- iii. Question: There is no reference to the size of the AGENT storage needed. Does this need to come out of the 16,000 SF?

Response: The only storage required is the Equipment Storage Building which is 1,190 SF. This was taken out of the 20,212 SF given in the 1391.

- iv. Question: Who is providing the SCBA compressor?? Is it GFGI?? Please advise.

Response: The SCBA compressor will be CFCI.

** NOTE: The compressor should meet the following minimum requirements:

At least 25.2 CFM Charging Rate
Minimum of 6000 PSI, 5 stages
Medical Grade Purification
NFPA 1901 Compliant

- b. Extend the proposal proposal due date to 12:00 pm, local time, Huntsville, AL, 19 August 2008.

(End of Summary of Changes)