

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
			J	1	4
2. AMENDMENT/MODIFICATION NO. 0003	3. EFFECTIVE DATE 26-Jul-2011	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY NAVFAC SOUTHEAST IPT SOUTH CENTRAL BLDG 135, PO BOX 30 NAS JACKSONVILLE JACKSONVILLE FL 32212-0030	CODE N69450	7. ADMINISTERED BY (If other than item 6)		CODE	
		See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. N69450-11-R-1762	
			X	9B. DATED (SEE ITEM 11) 29-Jun-2011	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.					
<p>Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:</p> <p>(a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
<p>The purpose of this amendment is to make the following changes: specifications and drawings have been revised and are posted to NECO; new MACS Form and Pre-proposal Conf/Site Visit documentation have been posted to NECO. All other terms and conditions remain unchanged.</p>					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		26-Jul-2011	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0003

A new MACS form for base access to NAS Jacksonville has been posted to NECO under the Additional Documents section. The new Excel format replaces the previous Adobe format.

The Pre-Proposal Conference and Site Visit attendance roster, minutes, and agenda, have been posted to NECO under the Additional Documents section.

The Past Performance Questionnaire (PPQ) is posted to NECO under the Additional Documents Section.

MCLB, Building 2200 Lobby Renovation. The following changes have been made to the RFP documents and are included in this amendment (posted to NECO as Additional Documents):

Specification Changes:

1. Section 08 81 00, Page 4, Par 2.1.1: after "45" in the first sentence "or 90" has been added.
2. Section 08 81 00, Page 4, Par 2.1.1: added at the end of the paragraph: "Wire glass windows in 45 minute doors shall not exceed 1,296 sq. in. and not exceed 54 inches in height or width. Wire glass windows in 1 ½ hour doors shall not exceed 100 sq. in. and not more than 10 inches in width and 33 inches in height.
3. Section 09 90 00, page 9, Par 1.9.3.1.a: in the last sentence change: "20 foot" to "10 foot".
4. Section 09 90 00, page 9, Par 1.9.3.1.b: in the last sentence change: "20 foot" to "10 foot".
5. Section 01 35 26, Page 9, Par 1.13: First Paragraph, fourth sentence: Change "4A:20 BC" to "10A:120 BC".
6. Section 01 35 26, Page 9, Par 1.13: First Paragraph last sentence: Change "30 minutes" to "1 hour".
7. Section 01 35 26, Page 9, Par 1.13: Second Paragraph, add to the end of the first sentence: "229-639-5500".
8. Section 01 35 26, Page 9, Par 1.13: Second Paragraph, add to the end of the last sentence: "from cell phones call 229-639-5500".
9. Section 01 35 26, Page 16, Par 3.9.1: Add the following Paragraph before the first Paragraph: "Work on energized equipment shall not be permitted. All work performed on or near exposed electrical systems shall comply with Policy Statement 3-08 included with this specification.
10. Section 01 35 26, Page 17, Par 3.9.1: Remove the last sentence from the paragraph, "All work performed on or near exposed energized electrical systems shall comply with Policy Statement 3-08 included with this specification. "
11. Section 01 35 26, end of Section: Policy Statement 3-08 included in full.
12. Section 21.13.13.00 Paragraph 1.3.3: Modified paragraph to read "0.2 gpm per sq ft" instead of "2 gpm per sq ft."
13. Section 12.48.13.13 Add to at the end of Par 2.2.1.1 "Mat shall be manufactured by one of the following manufacturers:
 1. American Floor Products Company, Inc.
 2. ARDEN Architectural Specialties, Inc.
 3. Balco, Inc.
 4. Cactus Mat Mfg. Co.

5. K. N. Crowder Manufacturing, Inc.
6. C/S Group.
7. Durable Corporation.
8. J. L. Industries, Inc.
9. Kadee Industries, Inc.
10. Matco International.
11. Musson, R. C. Rubber Co.
12. Pawling Corporation; Architectural Products Division.
13. Reese Enterprises, Inc.”
14. Recycle specification is added.
15. Quality Control specification is added.

Drawing Changes:

1. A102: Drawing is revised to show new door vision glass on door 101J. Revision 1. Replace drawing A102 in set with new A102, Revision 1.
2. A201: Drawing is revised to show new door vision glass on door 101J and modified note 12. Revision 1. Replace drawing A201 in set with new A201, Revision 1.

MCLB, Building 2200, Snack Bar Renovation. The following changes have been made to the RFP documents and are included in this amendment (posted to NECO as Additional Documents):

Specification Changes:

1. Section 02 82 16.00 20, Page 5, Par 1.3.1: the word “Lobby” has been changed to “Snack Bar”.
2. Section 02 82 16.00 20, Page 11, Par 1.5.6: the word “Lobby” has been changed to “Snack Bar”.
3. Section 02 82 16.00 20, Page 16, Par 3.2: the word “Lobby” has been changed to “Snack Bar” twice.
4. Section 02 82 16.00 20, Page 18, Par 3.2.6.3: the word “Lobby” has been changed to “Snack Bar”.
5. Section 08 81 00, Page 4, Par 2.1.1: after “45” in the first sentence “or 90” has been added.
6. Section 08 81 00, Page 4, Par 2.1.1: added at the end of the paragraph: “Wire glass windows in 45 minute doors shall not exceed 1,296 sq. in. and not exceed 54 inches in height or width. Wire glass windows in 1 ½ hour doors shall not exceed 100 sq. in. and not more than 10 inches in width and 33 inches in height. “
7. Section 09 90 00, page 9, Par 1.9.3.1.a: in the last sentence change: “20 feet” to “10 feet” .
8. Section 09 90 00, page 9, Par 1.9.3.1.b; in the last sentence change: “20 feet” to “10 feet”.
9. Section 01 35 26, Page 9, Par 1.3: First Paragraph, fourth sentence: Change “4A:20 BC” to “10A:120 BC”.
10. Section 01 35 26, Page 9, Par 1.13: First Paragraph last sentence: Change “30 minutes” to “1 hour”.
11. Section 01 35 26, Page 9, Par 1.13: Second Paragraph, add to the end of the first sentence: “(229-639-5500)”.
12. Section 01 35 26, Page 9, Par 1.13: Second Paragraph, add to the end of the last sentence: “from cell phones call (229-639-5500)”.
13. Section 01 35 26, Page 16, Par 3.9.1: Add the following Paragraph before the first Paragraph: “Work on energized equipment shall not be permitted. All work performed on or near exposed electrical systems shall comply with Policy Statement 3-08 included with this specification.
14. Section 01 35 26, Page 17, Par 3.9.1: Remove the last sentence from the paragraph, “All work performed on or near exposed energized electrical systems shall comply with Policy Statement 3-08 included with this specification. “
15. Section 01 35 26, end of Section: MCLB Policy Statement 3-08 included in full.
16. Section 22 00 00 Paragraph 2.1: Deleted all references to polypropylene pipe. Modified paragraph 2.1 deleted the following: “Polypropylene pipe and fittings shall conform to dimensional requirements of Schedule 40, Iron Pipe size and shall comply with NSF/ANSI 14, NSF/ANSI 61 and ASTM F 2389. Polypropylene piping that will be exposed to UV light shall be provided with a Factory applied UV resistant coating.”

Deleted paragraph 2.1.1 u.

Modified paragraph 3.9 Table II: Deleted item 25 (renumbered remaining items 25 through 30)

17. Section 21 13 13.00 20 Paragraph 1.3.3: Modified paragraph to read “0.2 gpm per sq ft” instead of “2 gpm per sq ft.”
18. Recycle specification is added.
19. Quality Control specification is added.

Drawing Changes:

1. A102: Drawing revised to show new door vision glass on door 127A. Revision 1. Replace drawing A102 in set with drawing A102, Revision 1.
2. A201: Drawing revised to show new door vision glass on door 127A. Revision 1. Replace drawing A201 in set with drawing A201, Revision 1.
3. M101: Revision 1. Replace drawing M101 in set with drawing M101, Revision 1.
4. M103: Revision 1. Replace drawing M103 in set with drawing M103, Revision 1.
5. M201: Revision 1. Replace drawing M201 in set with drawing M201, Revision 1.
6. M301: Revision 1. Replace drawing M301 in set with drawing M301, Revision 1.

(End of Summary of Changes)