

#	Date	Section; Page; Paragraph	Question	Government Response	Change RFP (Y/N)	Amend #
				Changes to previous entries are in red font		
1	7-Jun-11		Please provide the GIS map of the entire base in AutoCAD format if available.	SEE ATTACHMENT "MCLB ALBANY GIS MAP"	N	N/A
2	7-Jun-11		Will there be any buildings/areas that need to be backed up by a generator during an outage?	YES, GENERATORS WILL BE REQUIRED	N	N/A
3	7-Jun-11		Please provide a one line diagram of the base electrical system if available.	NOT AVAILABLE AT THIS TIME	N	N/A
4	7-Jun-11	Reference RFP Small Project Part 3, Chapter 6, Additional Requirements, Page 9 of 9:	The second sentence in the fourth paragraph indicates "Provide metering of all circuits affected by this project per base standards, including but not limited to: circuits 20, 40, 2011, 3011, 3012, 3013, 5011 and 5012." Is it the intent to provide primary metering of all of these circuits at their substation origin? This will result in 8 primary metering cabinets. Please provide the base standard for metering as well. Will any of the meters require remote monitoring, and if so what is the protocol?	REQUIREMENT DELETED	Y	3
5	7-Jun-11	Reference RFP Small Project Part 3, Chapter 6, Base, Section 1, Page 3 of 9:	If any of the sub-circuits require re-cabling, such as circuit 2011, is the conductor size to remain as 500KCMIL or will smaller conductor sizes be allowed?	ONLY LATERALS SHALL BE SMALLER THAN 500kcmil	N	N/A