

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE OF PAGES 1 4
2. AMENDMENT/MODIFICATION NO. 0004		3. EFFECTIVE DATE Jun 22, 2011	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)	
6. ISSUED BY CODE		N69450	7. ADMINISTERED BY (If other than Item 6)		CODE
NAVFAC SOUTHEAST, IPT SC, AJAX ST, PO BOX 30, BLD 135, JACKSONVILLE FL 32212-0030 Melissa.a.Finnell@NAVY.MIL (904) 542-0158					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO.
				<input checked="" type="checkbox"/>	N69450SOW0030
					9B. DATED (SEE ITEM 11) May 23, 2011
					10A. MODIFICATION OF CONTRACT/ORDER NO.
				<input type="checkbox"/>	10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

RFP FOR SOW #0030, SC/GA MINI-MACC N69450-08-D-1779/1780/1781/1782 & 09-D-1760
Circuit 20 West, MCLB Albany, Georgia

The RFP has been amended as follows:
The PPI Log has been attached with answers to recent PPIs.

Continued on Page 2

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

#	Date	Section; Page; Paragraph	Question	Government Response	Change RFP?	Amendment
1	6/7/11		Please provide the GIS map of the entire base in AutoCAD format if available.	SEE ATTACHMENT "MCLB ALBANY GIS MAP"	N	N/A
2	6/7/11		Will there be any buildings/areas that need to be backed up by a generator during an outage?	YES, GENERATORS WILL BE REQUIRED	N	N/A
3	6/7/11		Please provide a one line diagram of the base electrical system if available.	NOT AVAILABLE AT THIS TIME	N	N/A
4	6/7/11	Reference RFP Small Project Part 3, Chapter 6, Additional Requirements, Page 9 of 9:	The second sentence in the fourth paragraph indicates "Provide metering of all circuits affected by this project per base standards, including but not limited to: circuits 20, 40, 2011, 3011, 3012, 3013, 5011 and 5012." Is it the intent to provide primary metering of all of these circuits at their substation origin? This will result in 8 primary metering cabinets. Please provide the base standard for metering as well. Will any of the meters require remote monitoring, and if so what is the protocol?	REQUIREMENT DELETED	Y	3
5	6/7/11	Reference RFP Small Project Part 3, Chapter 6, Base, Section 1, Page 3 of 9:	If any of the sub-circuits require re-cabling, such as circuit 2011, is the conductor size to remain as 500KCMIL or will smaller conductor sizes be allowed?	ONLY LATERALS SHALL BE SMALLER THAN 500kcmil	N	N/A
6	6/1/11	RFP Factor 2, Sub-Paragraph (a), line 3,	requires for all past performance submissions the Offer is to have "completed and served as prime contractor." However, RFP Factor 1, Definition of a Relevant Project, and Factor 1, Qualifications, do not define a Relevant Project as having been completed by the Offeror as the Prime Contractor. Please clarify the RFP Prime Contractor past performance and relevant experience requirements with regards to the Offeror.	Relevant project are projects that are completed by Offeror as the Prime Contractor. In-addition NAVFAC will recognize a qualified Contractor/Offeror "Team" formed under the Team Definition at FAR 9.601(2)	N	N/A
7	6/1/11	RFP Factor 1 - Qualifications, Sub-Paragraph (a), Submittal Requirements:	Will NAVFAC allow one or more of the relevant projects listed on the two required resumes to have been performed by the individual(s) while in the employ of a contractor other than the Offeror?	Yes we will allow this.	N	N/A

8	6/1/11		<p>Will NAVFAC recognize as responsive a qualified Contractor/Offeror "Team" formed under the Team Definition at FAR 9.601(2) (see below) and submitted in response to the RFP Part B, Technical Factors and Factor 2, Past Performance? Subpart 9.6-Contractor Team Arrangements</p> <p>9.601 Definition. "Contractor team arrangement," as used in this subpart, means an arrangement in which-</p> <p>(1) Two or more companies form a partnership or joint venture to act as a potential prime contractor; or</p> <p>(2) A potential prime contractor agrees with one or more other companies to have them act as its subcontractors under a specified Government contract or acquisition program.</p> <p>9.602 General. (a) Contractor team arrangements may be desirable from both a Government and industry standpoint in order to enable the companies involved to-</p> <p>(1) Complement each other's unique capabilities; and</p> <p>(2) Offer the Government the best combination of performance, cost, and delivery for the system or product being acquired.</p> <p>(b) Contractor team arrangements may be particularly appropriate in complex research and development acquisitions, but may be used in other appropriate acquisitions, including production.</p> <p>(c) The companies involved normally form a contractor team arrangement before submitting an offer. However, they may enter into an arrangement later in the acquisition process, including after contract award.</p> <p>9.603 Policy. The Government will recognize the integrity and validity of contractor team arrangements; provided, the arrangements are identified and company relationships are fully disclosed in an offer or, for arrangements entered into after submission of an offer, before the arrangement becomes effective. The Government will not normally require or encourage the dissolution of contractor team arrangements.</p>	<p>Yes we will accept. The "Team" has to be identified in the proposal, and the "team" has to execute the project during design and construction.</p>	N	N/A
9	6/1/11		<p>PART 2, General Requirements, item 17 refers to the need to verify on-site utilities via locates/dig permits during the construction coordination. Question: During the RFP process, will CAD electronic files or Print drawings of the Existing Underground Utilities be provided for design/pricing coordination as attachment to PART 6? This information will be necessary in order to ensure adequate design coordination between existing and new work.</p>	<p>Contractor/Offeror will have to use a locating service as needed for the proposal.</p>	N	N/A
10	6/15/11	Reference PPI log Response no. 1:	<p>Original Request: Please provide the GIS map of the entire base in AutoCAD format if available. Response: SEE ATTACHMENT "MCLB ALBANY GIS MAP" The file sent was actually a one line diagram, which had many reference files that were not included in the file sent. Please re-send the file make sure to "bind" all reference files prior to sending.</p>	<p>MCLB Albany is in the process of executing a single line project at this time. The data provided is the only data we have at this time.</p>	N	N/A
11	6/15/11	Reference RFP Section G40/PPI Log	<p>Since an official one line diagram, please provide the number of taps are on each feeder in each section in each area. For example, how many taps are off of the line in area 1, section 5, that is going from underground to overhead.</p>	<p>Same as above</p>	N	N/A

		response no. 3:				
12	6/15/11	Reference PPI Log Response No. 1:	The response indicated that some buildings will require generator power during outages. Please provide the building numbers in service type and size so that the cost of proper generator(s) can be provided.	Number of buildings that will require a generator is not available.	N	N/A
13	6/15/11	Reference RFP Small Project Part 3, Chapter 6, Base, Section 1, Page 3 of 9:	If any of the sub-circuits require re-cabling, such as circuit 2011, is the conductor size to remain as 500KCMIL or will smaller conductor sizes be allowed?	Remain 500KCMIL	N	N/A
14	6/15/11		Due to fact the GIS map has yet to be provided and the bid date of July 7 falls after a holiday weekend when prices will need to be pulled together, we would like to request a one week extension for a bid date of July 14.	The proposal due date remains 7/7/11.	N	N/A