

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 2
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE May 25, 2010	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)	
6. ISSUED BY NAVFAC SOUTHEAST, IPT SC, AJAX ST, PO BOX 30, BLD 135, JACKSONVILLE FL 32212-0030 ROBERT.WOOLWINE@NAVY.MIL (904) 542-6325	CODE N69450	7. ADMINISTERED BY (If other than Item 6)		CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. SOW #0025
			<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) Apr 30, 2010
				10A. MODIFICATION OF CONTRACT/ORDER NO.
			<input type="checkbox"/>	10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

P360 ELECTRICAL SUBSTATION, MCRD PARRIS ISLAND, SC. RFP FOR SOW #0025, WORK ORDER #796570, MACC N69450-08-D-1779/1780/1781/1782 & 09-D-1760.

continued on page 2.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

The following changes are made to the RFP:

Part 3, Project Program

3.2 Site Development Requirements

Change the second to last paragraph from:

“This substation is considered a low occupancy site and is therefore exempt from AT/FP requirements.”

To:

“This substation is considered a low occupancy site.”

Part 3 Project Program

Paragraph 6 ENGINEERING SYSTEMS REQUIREMENTS

G401008 GROUNDING SYSTEMS

Change the first paragraph from:

“Provide a complete grounding system for the electrical power distribution system.”

To:

“Provide a complete grounding system for the electrical power distribution system outside the SCE&G fenced substation compound area. Connect to SCE&G provided grounding grid pigtail to be located 3’ outside SCE&G fence line”

Part 3 Project Program

Paragraph 6 ENGINEERING SYSTEMS REQUIREMENTS

G403001 TELECOMMUNICATION SYSTEMS

Change the third paragraph, second sentence from:

“Provide a NEMA 4X enclosure (“Telecommunications Interface Box”) to facilitate telecommunications connections run between the SCE&G Co substation and the MCRD’s facilities.”

To:

“Provide a NEMA 4X enclosure (“Telecommunications Interface Box”) to facilitate telecommunications connections run between the SCE&G Co substation, intelligent electronic devices (see G401003) and the MCRD’s facilities.”

All other terms and conditions remain unchanged. Date and time for receipt of proposals is unchanged.