

| | | | | |
|---|-----------------------------------|---|--------------------------------|--|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | 1. CONTRACT ID CODE | PAGE OF PAGES 1 7 |
| 2. AMENDMENT/MODIFICATION NO. 0004 | 3. EFFECTIVE DATE Jul 12, 2010 | 4. REQUISITION/PURCHASE REQ. NO. | 5. PROJECT NO. (if applicable) | |
| 6. ISSUED BY NAVFAC SOUTHEAST, IPT SC, AJAX ST, PO BOX 30, BLD 135, JACKSONVILLE FL 32212-0030 ROBERT.WOOLWINE@NAVY.MIL (904) 542-6325 | CODE N69450 | 7. ADMINISTERED BY (if other than item 6) | | CODE |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) | | | (X) | 9A. AMENDMENT OF SOLICITATION NO. SOW #0025 |
| | | | (X) | 9B. DATED (SEE ITEM 11) Apr 30, 2010 |
| | | | | 10A. MODIFICATION OF CONTRACT/ORDER NO. |
| | | | | 10B. DATED (SEE ITEM 13) |
| CODE | FACILITY CODE | | | |

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

| | | |
|--------------------------|---|---|
| CHECK ONE | A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) NO. IN ITEM 10A. | THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER |
| <input type="checkbox"/> | B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). | |
| <input type="checkbox"/> | C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: | |
| <input type="checkbox"/> | D. OTHER (Specify type of modification and authority) | |

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

P360 ELECTRICAL SUBSTATION, MCRD PARRIS ISLAND, SC. RFP FOR SOW #0025, WORK ORDER #796570, MACC N69450-08-D-1779/1780/1781/1782 & 09-D-1760.

The purpose of this amendment is to revise the RFP and to open discussions with offerors. Discussion letters will be sent under separate cover. Date and time specified for receipt of revised offers is set for 27 Jul 2010, 2:00PM.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

| | | | |
|---|--|---|--|
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | |
| 15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign) | | 16B. UNITED STATES OF AMERICA (Signature of Contracting Officer) | |
| 15C. DATE SIGNED | | 16C. DATE SIGNED | |

The following changes are made to the RFP:

1. The definition of a relevant project is clarified as follows:

For corporate experience, only the first five projects submitted will be evaluated. This includes the prime contractor and any subcontractor projects. All portions of the relevant project definition do not need to be included in a single project. However, the total projects submitted (minimum of two, maximum of five) must include all aspects of the relevant project definition.

For Key Personnel resumes, all portions of the relevant project definition do not need to be included in a single project, but the total projects submitted (limited to two pages) must include all aspects of the relevant project definition and demonstrate the minimum number of years of experience. The Electrical and Civil Engineers need to provide only projects that demonstrate experience with their portions of the project, but must also demonstrate specialized experience as required by the RFP.

2. Wage determination SC100020 03/12/2010 SC20 is removed and replaced with the following:

General Decision Number: SC100010 03/12/2010 SC10

Superseded General Decision Number: SC20080010

State: South Carolina

Construction Types: Heavy (Heavy and Sewer and Water Line)

Counties: Abbeville, Allendale, Bamberg, Barnwell, Beaufort, Calhoun, Cherokee, Chester, Chesterfield, Clarendon, Colleton, Darlington, Dillon, Edgefield, Fairfield, Georgetown, Greenwood, Hampton, Horry, Jasper, Kershaw, Lancaster, Laurens, Lee, Marion, Marlboro, McCormick, Newberry, Oconee, Orangeburg, Saluda, Sumter, Union and Williamsburg Counties in South Carolina.

IN ALLENDALE AND BARNWELL COUNTIES, DOES NOT INCLUDE THE SAVANNAH RIVER SITE

HEAVY CONSTRUCTION PROJECTS (includes sewer & water line projects)

| Modification Number | Publication Date |
|---------------------|------------------|
| 0 | 03/12/2010 |

* SUSC1990-005 02/08/1990

Rates Fringes

| | | |
|---|----------|-------|
| Boilermaker (tank work)..... | \$ 12.96 | 3.315 |
| Bricklayer..... | \$ 7.25 | |
| Carpenter..... | \$ 7.42 | |
| Cement mason/concrete finisher..... | \$ 7.25 | |
| Ironworker..... | \$ 10.98 | |
| Laborers: | | |
| _Chain saw..... | \$ 7.25 | |
| _General..... | \$ 7.25 | |
| _Pipelayer..... | \$ 7.25 | |
| Pipefitter..... | \$ 9.09 | |
| Power equipment operators: | | |
| _Backhoe..... | \$ 7.25 | |
| _Bulldozer..... | \$ 7.25 | |
| _Crane..... | \$ 7.98 | |
| _Dragline..... | \$ 7.25 | |
| _Front end loader..... | \$ 7.25 | |
| _Mechanic..... | \$ 7.25 | |
| _Motor grader..... | \$ 7.25 | |
| _Scraper - pan..... | \$ 7.25 | |
| Truck driver..... | \$ 7.25 | |
| Line Construction: line technician..... | \$ 10.08 | |
| MANHOLE BUILDER..... | \$ 7.25 | |

WELDERS - Receive rate prescribed for craft performing operation to which welding is incidental.
=====

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (ii)).

In the listing above, the "SU" designation means that rates listed under the identifier do not reflect collectively bargained wage and fringe benefit rates. Other designations indicate unions whose rates have been determined to be prevailing.

WAGE DETERMINATION APPEALS PROCESS

1.) Has there been an initial decision in the matter? This can be:

- * an existing published wage determination
- * a survey underlying a wage determination
- * a Wage and Hour Division letter setting forth a position on a wage determination matter
- * a conformance (additional classification and rate) ruling

On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour Regional Office for the area in which the survey was conducted because those Regional Offices have responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

Branch of Construction Wage Determinations
Wage and Hour Division
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

2.) If the answer to the question in 1.) is yes, then an interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board
U.S. Department of Labor
200 Constitution Avenue, N.W.
Washington, DC 20210

4.) All decisions by the Administrative Review Board are final.

=====

END OF GENERAL DECISION

3. Part 3, Project Program
3.2 Site Development Requirements

Add paragraphs to end of section:

“The Substation raised site shall have a slope of approximately 0.5% from its centerline to the edge of the site. Side slopes from the elevated site to the natural grade shall be 5 to 1. The site grade slope toward the road shall not exceed 8%. There shall be no open retention or detention basins for the project.

Relocated overhead power poles are to be placed on the outside of the roadway curve and outside of the clear zone for the new roadway. All replacement power poles at the site and across the Depot are to be installed on the outside of the existing pole away from the existing road pavement. At no time shall a replacement pole be placed closer to existing roads/sidewalks than existing poles.”

4. Part 3, Project Program
Chapter 6, Engineering Systems Requirements
G2010 ROADWAYS

Add paragraph to end of section:

“Roadway elevation may vary between nine and ten feet, but is not to go below nine feet. Roadway elevation in front of the substation site shall not be less than 9.5 feet”

5. Part 3, Project Program
Chapter 6, Engineering Systems Requirements
G40 SITE ELECTRICAL UTILITIES
GENERAL SYSTEM REQUIREMENTS

Add paragraph to end of section:

“Reference UFC 3-560-01 Chapter 8 for criteria regarding working on energized electrical circuits. It is not permitted on circuits operating at 50 V or more except when required to support a critical mission, prevent human injury, or protect property.”

6. Part 3, Project Program
Chapter 6, Engineering Systems Requirements
G401004 OVERHEAD ELECTRIC CONDUCTORS

Change the first and second paragraphs from:

"Provide overhead Feeder (called Circuit "I" for the purposes of this RFP, coordinate naming convention with MCRD). Extend from SF6 gear to Panama Street as indicated in Part 6 of this RFP. Connect new circuit to existing overhead feeder circuit. Overhead conductors shall be # 4/0

with fully rated neutral. See Part 6 "E" sheets for additional information on configuration, electrical system architecture and notional locations.

Provide overhead feeder (called Circuit "G" for the purposes of this RFP, coordinate naming convention with MCRD). Extend from SF6 gear to Atsugi Street as indicated in Part 6 of this RFP. Rebuild circuit from Atgusi to Panama Street. Demolish and provide new poles, pole accessories, guying, site lighting, fused cutouts, arrestors, etc. overhead conductors shall be # 4/0 with neutral. Reconnect all radial and tap connections. See Part 6 "E" sheets for additional information on configuration, electrical system architecture and notional locations."

To:

"Provide overhead Feeder (called Circuit "I" for the purposes of this RFP, coordinate naming convention with MCRD). Extend from SF6 gear to Panama Street as indicated in Part 6 of this RFP. Connect new circuit to existing overhead feeder circuit. Overhead conductors shall be # 4/0 copper with fully rated neutral. See Part 6 "E" sheets for additional information on configuration, electrical system architecture and notional locations.

Provide overhead feeder (called Circuit "G" for the purposes of this RFP, coordinate naming convention with MCRD). Extend from SF6 gear to Atsugi Street as indicated in Part 6 of this RFP. Rebuild circuit from Atgusi to Panama Street. Demolish and provide new poles, pole accessories, guying, site lighting, fused cutouts, arrestors, etc. overhead conductors shall be # 4/0 copper with neutral. Reconnect all radial and tap connections. See Part 6 "E" sheets for additional information on configuration, electrical system architecture and notional locations."

7. Part 3, Project Program
Chapter 6, Engineering Systems Requirements
G401004 OVERHEAD ELECTRIC CONDUCTORS

Add paragraph to end of section:

“Relocate all secondary (low voltage, site lighting and related) and all communication lines (fiber, coaxial, and copper telephone cables) from existing poles to new poles.”

8. Part 3, Project Program
Chapter 6, Engineering Systems Requirements
G4020 SITE LIGHTING

Change first paragraph from:

“Provide site lighting for exterior substation for security purposes. Provide distribution, handholes, grounding, poles, fixtures and controls as required for a complete and usable system.”

To:

“Provide site lighting for exterior substation for security purposes. Provide lighting for areas of MCRD equipment only, not to light up the entire substation. Provide distribution, handholes, grounding, poles, fixtures and controls as required for a complete and usable system.”

9. All other terms and conditions remain unchanged. ACKNOWLEDGEMENT OF THIS AMENDMENT IS REQUIRED WITH THE REVISED PROPOSAL.